

## **BRE Certification Limited and LPCB**

Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX  
Telephone: 01923 664100 Fax: 01923 664603 E-mail: [enquiries@bre-certification.co.uk](mailto:enquiries@bre-certification.co.uk) Web: [www.bre-certification.co.uk](http://www.bre-certification.co.uk)

### **EC-CERTIFICATE OF CONFORMITY**

**0832 - CPD - 0632**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

**MPD821 Conventional photoelectric smoke detector for use in fire detection and alarm systems**

*(For conditions of use for the product see the attached appendix)*

placed on the market by

**Cooper Industries Inc.  
Wheatley Hall Road, Doncaster, South Yorkshire, DN2 4NB**

and produced in the factory

**Digital Lighting (Dongguan) Co., Ltd  
Xin Min Road, Xin Min District, Changan Town, Dongguan City, Guangdong Province, China  
523879**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Certification Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

**EN 54 - 7: 2000 + A1: 2002 - Fire detection and fire alarm systems - Smoke detectors - Point detectors using scattered light, transmitted light or ionization**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 11/2/2008 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Paul Stevens  
For and on behalf of BRE Certification Limited

Date of Issue: 11/2/2008  
Issue Number: 1  
Page: 1 of 2

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.  
To check the authenticity of this certificate, please visit our website or contact us.

## **BRE Certification Limited and LPCB**

*Bucknalls Lane, Garston, Watford, Hertfordshire, WD25 9XX*

*Telephone: 01923 664100 Fax: 01923 664603 E-mail: enquiries@bre-certification.co.uk Web: www.bre-certification.co.uk*

### **Appendix to EC Certificate of conformity 0832 - CPD - 0632**

The details and conditions of use for the MPD821 Conventional photoelectric smoke detector, placed on the market by Cooper Industries Inc. are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

**Bases:**

MDB800 Standard base

Paul Stevens  
For and on behalf of BRE Certification Limited



Date of Issue: 11/2/2008  
Issue Number: 1  
Page: 2 of 2

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.  
To check the authenticity of this certificate, please visit our website or contact us.